

Consulting Analytical & Industrial Chemists
 Specialists in Water & Waste Water Treatment
 Telephone (021)448 6340/1
 After Hours (021)712 0940
 Telefax (021)448 6342
 e-Mail Address :
 info@alabbott.co.za



No. 1, Vine Park
 Vine Road
 7925
 P.O. Box 483
 WOODSTOCK, CAPE
 7915

Certificate of Analysis

SWARTLAND MUNICIPALITY
Swartland Municipality Final Effluent
Final Effluent ex Chatsworth

DATE SAMPLED : 2017/01/08
DATE RECEIVED : 2017/01/09
DATE ANALYSIS
COMMENCED : 2017/01/09

OUR REF. : 2017/01/08/347
REPORT NO. : 53

	Sample Number	347	
Mthd ALA No.	Analyses	Results	General Limit (Full)
19	pH (at 25 °C)	7.20	5.5-9.5
9	Conductivity (mS/m) (at 25 °C)	132	70.0 Above Intake - 150 Max
2	Chemical Oxygen Demand (mg/l)	114	75.0 After Removal of Algae
2	Chemical Oxygen Demand (Filtered) (mg/l)	109	75.0
95	Ammonia Nitrogen (mg/l as N)	29.7	6.0
100	Nitrate Nitrogen. (mg/l as N)	<0.20	15.0 (sum of NO ₂ & NO ₃ -N)
99	Nitrite Nitrogen (mg/l as N)	0.51	15.0 (sum of NO ₂ & NO ₃ -N)
6A	Total Suspended Solids (mg/l)	12	25
101	Ortho Phosphate (mg/l as P)	9.1	10.0
86	Faecal Coliforms (count per 100 ml)	1	1000

N. VAN BINSBERGEN (Pr.Sci.Nat.)
 DIRECTOR
 12 January 2017

TO: SWARTLAND MUNICIPALITY
 P O Box 52
 MALMESBURY
 7300

Att: MR L. ZIKMAN