

Withoogte Bulk Water Distribution System Projected Water Requirements (KI/a)						
Year *	System Input Volume Supplied to Swartland Municipality			Total Projected System Input Volumes for all Towns Supplied by System		
	Moorreesburg	Koringberg	System Input Volume	WSDP Model	Low Growth	High Growth
2003	759 670	39 878	799 548			
2004	672 255	42 388	714 643			
2005	755 340	47 543	802 883			
2006	840 580	58 136	898 716			
2007	822 940	57 829	880 769			
2008	803 680	62 809	866 489			
2009	797 450	85 766	883 216			
2010	762 024	59 952	821 976			
2011	827 492	48 167	875 659			
2012	784 940	62 777	847 717			
2013	778 942	56 936	835 878			
2014	860 288	69 202	929 490			
2015	779 557	64 578	844 135			
2016	659 185	60 128	719 313			
2017	480 789	44 157	524 946			
2018	532 506	46 609	579 115			
2019	590 106	51 908	642 014			
2020	671 591	56 412	728 003	734 747	728 003	728 003
2025				810 270	803 774	885 727
2030				940 189	887 432	1 077 622
2035				1 093 753	979 796	1 311 092
2040				1 275 521	1 081 774	1 595 144
2045				1 490 953	1 194 366	1 940 737

Notes: (\*) The years in the above table refer to the Municipal Financial Years and is for the period July till June the following year. The measured demand for 2020 is therefore from July 2020 up to June 2021.

